



NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 391-06-E

Manufacturer: Lennox Industries Inc.
200 South 12th Avenue
Marshalltown, IA 50158

Trade Name(s): Lennox Industries

Product: Gas-fired central furnaces for residential applications
MEA Index #370-30 – Furnaces

Pertinent Code Section(s): Subchapter 14

Prescribed Test(s): RS 14-6 (Z21.47a – 2004)

Laboratory: CSA International

Test Report(s): #1104995 issued June 7, 2007 and #1197796
issued February 26, 2008.

Description: Gas-fired central furnaces, models **G40UH**, **G50UH**, **G40DF** and **G50DF** are for residential applications. Units are suitable for downflow or upflow/horizontal configuration with electronic ignition for alcove, attic, closet or free-space installation.

Terms and Conditions: The above-described factory-built fireplaces are accepted for use as supplemental heating and decorative purposes under the following conditions:

1. Units are for residential use only.
2. The installation shall be in accordance with manufacturer-supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, units shall be vented in accordance with Section 27-856 of the Building Code.

3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance September 2, 2008.
Examined By Donald J. Jd