



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 392-06-E

Manufacturer: Fujitsu General America, 353 Route 46 West,
Fairfield, NJ 07004

Trade Name(s): Fujitsu

Product: Cooling variable refrigerant floor system

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995)

Laboratory: ETL Testing Laboratories

Test Report(s): No. 3073263-001, dated 9/17/05

Description: The product covered in this report consists of one outdoor unit using a DC inverter driven scroll compressor with variable capacity, 9 duct-type indoor units and 5 wall-mounted-type indoor units, wired or wireless remote controller, and variable refrigerant flow and control systems.

Manufacturer's Specified Cooling Capacity: 0.58-4.0 tons

Products Covered:

Condensing unit: AOU54RVJ (cooling and heating)
AOU48CVJ (cooling only)

Ducted type evaporators: ARU7BVJ, ARU12BVJ, ARU14BVJ, ARU18BVJ, ARU25BVJ, U30BVJ, ARU36BVJ, and ARU45BVJ.

Wall -mounted type evaporators: ASU7BVJ, ASU9BVJ, ASU12BVJ, ASU14BVJ, and ASU18BVJ

Network Converter: UTR-YGCA.

Terms and Conditions: The above- described units are accepted, under the following conditions:

1. Units shall use Refrigerant 410A only.
2. All equipment shall be furnished with a permanently affixed metal tag, stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 8/11/06

Examined By Shyam. Prasad