



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 398-07-M

Manufacturers:

Euro Panels Overseas N.V.
Bormstraat 22, B-2830 Willebroek
Belgium

&

American Fiber Cement Corp.
6901 S. Pierce Street, Suite 260
Littleton, CO 80128

Trade Name(s):

Eter-Color

Product:

Non-combustible façade panel

Pertinent Code Section(s):

27-348, 27-335-1

Prescribed Test(s):

RS 5-5 (ASTM E136), Toxicity

Laboratory:

SGS U.S. Testing Company, Inc. (SGS)
Anderson Laboratories, Inc. (AL)

Test Report(s):

SGS Test #177:007388
AL Test #668, dated October 1, 2007.

Description: Eter-Color is a non-flammable, through-colored, fiber cement board for façade and exterior/interior cladding. Eter-color has a high-resistance to severe weather conditions as well as chemicals and living organisms. Eter-color panel has 6mm and 8mm thickness in trimmed and untrimmed sizes, available in various colors and retains the ASTM E136 and toxicity rating per building code requirements.

Terms and Conditions: The above-described panel is accepted for interior and exterior finish usage with the following conditions:

1. Panel is to be hung in accordance with the New York City Building Code.
2. All safety precautions must be adhered to when hanging panel in accordance with OSHA standards or Building Department standards, whichever provides the highest degree of safe handling.
3. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials are equivalent to those tested and accepted for use, as provided for in Article 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 23, 2008

Examined By Sian Derkhdam