

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 4-03-E

Report of Material and Equipment Acceptance Division

Manufacturer—System Sensor, 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name —System Sensor.

Product — Fire Alarm Equipment.

Pertinent Code Section(s) — Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Tests — UL 864.

Laboratory — Underwriters Laboratories, Inc.

Test Reports — UL file S3705 Volume 2, Section 3, issued July 13, 2001, revised October 18, 2002.

Description — The Model 2W-MOD maintenance module is intended to be connected to the Models 2W-B and 2WT-B smoke detectors. The module can also be connected to compatible 2-wire, conventional smoke detectors; however, the maintenance trouble feature of the module cannot be utilized. Styles D and B initiating device circuit wiring methods are supported. The module is connected directly to the initiating circuit of a compatible fire alarm control panel.

Model Number	Description
2W-MOD2	Maintenance Module

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated January 8, 2003, F.P. Index 0301001.

Recommendation - That the above equipment be accepted provided that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Codes, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

May 30, 2003

Examined by

[Handwritten Signature]