

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 404-00-M

Report of Material and Equipment Acceptance Division

Manufacturer - Roysons Corporation, 40 Vanderhoof Avenue, Rockaway, NJ 07866.

Trade Name - Roysons.

Product - Wallcovering material.

Pertinent Code Section(s) -27-348.

Prescribed Test(s) - RS 5-5 (ASTM E84); Toxicity.

Laboratory - SGS U.S. Testing Company, Inc.

Test Report(s) - U.S. Report No. 142502.002.01 dated August 11, 2000 and 142502-(1,3) dated July 28, 2000.

Description - Vinyl wallcovering, 20 oz. Roysons with a laminated cotton, polyester scrim backing, is for use in interior finish application.

Flame Spread Rating	15 - 20
Smoke Density Rating	100 - 125

Recommendation - That the above described wallcovering material be accepted as having interior finish Class A, with flame spread rating as indicated above.

Material with a greater smoke density of 25 shall not be used in exits or corridors. Material with greater smoke density of 50 shall not be used in Occupancy H-1 and H-2. Material with a greater smoke density of 100 shall not be used in rooms in which the net floor area per occupant is ten square feet or less. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Nov. 22, 2000

Examined By S Derkshidam