



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 415-03-E Vol. 2

Manufacturer: Gamewell, 12 Clintonville Road, Northford, CT 06472

Trade Name(s): Gamewell

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 through 27-977, Reference Standard RS 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S521, Projects 04ME08857 & 05ME04191, issued July 8, 2004, revised June 16, 2005

Description: The Identiflex 602 series addressable Fire Alarm Control Panels. These panels may also support releasing features or voice evacuation.

Model No.	Description
IF602-126XL	126 point addressable FACP in an extra large back box
IF602-252XL	252 point FACP in an extra large back box
IF602SS-198R	198 point FACP
IF602SS-396R	396 point FACP
IF602SS-198XL	198 point FACP in an extra large back box
IF602SS-396XL	396 point FACP in an extra large back box
IF602VE-126	126 point FACP with integral voice evacuation
IF602VE-252	252 point FACP with integral voice evacuation
IF602VE-126Z	126 point FACP with integral voice evacuation (8 outputs)
IF602VE-252Z	252 point FACP with integral voice evacuation (8 outputs)
IF602SSVE-198	198 point FACP with integral voice evacuation
IF602SSVE-396	396 point FACP with integral voice evacuation
IF602SSVE-198Z	198 point FACP with integral voice evacuation (8 outputs)
IF602SSVE-396Z	396 point FACP with integral voice evacuation (8 outputs)

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objection letters dated July 25, 2006, F.P. Index #0607044.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements, functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with Reference Standards RS 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendation and UL standards.
2. When used with the central office communicator or a transmitter (DACT), the installation and operation of the control unit equipment and devices shall comply with 3RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
4. Models with voice system shall have the capability of individual, group or entire building notification of alarm tone and voice intelligibility.
5. Installation of pre-recorded evacuation messages and background music would require a prior approval from the Department.
6. Auto alarm silencing feature shall be removed from all these control units.
7. The referenced control units shall not be used for carbon dioxide (C^{O2}) releasing applications.
8. All enclosing cases for above fire alarm equipment shall be painted red in color.
9. The above-referenced fire alarm control units shall be used only with listed and approved/accepted components and accessories with which the compatibility has been determined by the Engineer or Architect of Record or a UL test report.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance September 7, 2006
Examined By Donald [Signature]