

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 417-87-M Vol. V
Report of Material and Equipment Acceptance Division

Manufacturer - Conbraco Industries, Inc., P.O. Box 247, Matthews, NC 28106.

Trade Name - Conbraco.

Product - Double check valve backflow prevention assemblies.

Pertinent Code Section(s) - P107 18 of Reference Standard RS 16.

Prescribed Test(s) - RS 16 (ASSE No. 1015).

Laboratory - ASSE/Center for Irrigation Technology and IAPMO.

Test Report(s) - ASSE dated December 10, 1999 and December 21, 2000.

Description - Double check valve backflow prevention assemblies, DC Series, in sizes 8 and 10 inches, horizontal and vertical flow up, designed to prevent the reverse flow of pollutants into the potable water supply. The assemblies comprise two independently acting, spring loaded swing type check valves in a corrosion resistant ductile iron body. The unit is available with inlet and outlet shutoff valve, four test cock, three on the check valve body and one on the inlet shut off valve, complete the assembly.

Recommendation - That the above backflow prevention assemblies be accepted for use when installed in conformance with Reference Standard RS-16. All shipments and deliveries of such materials shall be accompanied by a metal tag certifying that the assembly shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March/25/04

Examined By S. D. [Signature]