

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

MEA 419-02-E Vol. III  
Report of Material and Equipment Acceptance Division

Manufacturer – PB Heat LLC, 9<sup>th</sup> & Rothermel Drive, P.O. Box 447, New Berlinville, PA 19545-0447.

Trade Name(s) – Peerless Boilers.

Product -Oil fired direct vent hot water boiler assemblies.

Pertinent Code Section(s) -27-800, 27-824, 27-886.

Prescribed Test(s) - RS 14-6 (UL726).

Laboratory – Intertek Testing Services.

Test Reports – File No. 3027380-003 dated September 19, 2002.

Description - Cast iron, direct vent, oil fired hot water boiler assemblies, WV-DV Series, designed for residential applications, for operation with not heavier than No. 2 fuel oil. Unit consists of burner with controls, heat exchanger assembly, combination temperature and pressure gauge, thermostat and ASME relief valve set at 30 psi, maximum. Units, are provided with a temperature limit control set. Units, with model numbers and fuel oil input ratings, are listed below.

Model No.	No. 2 Fuel Oil Input Rating GPH
WV-DV-03-075	.75
WV-DV-03-085	.85
WV-DV-03-110	1.10

Note: Boilers may be installed on noncombustible flooring only. Minimum installed clearances from combustible construction shall be in accordance with Reference Standard RS 14-15.

Recommendation - That the above described boilers, constructed in accordance with the ASME Code and assembled with compatible MEA accepted burner with size and operating characteristics approved by the boiler manufacturer, be accepted for use fired by No. 2 fuel oil as indicated in the table.

When connected to approved vent in accordance with Article 27-886 of Building Code. This acceptance in no way includes the external piping, connections, and appurtenances thereto, which are required to fully conform with applicable provisions of law, but have been tested in conjunction with this application. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April/30/04

Examined By S Deshpande