



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 419-05-E Vol. 2

Manufacturer: Lennox Hearth Products
503 East Reelfoot Avenue
Union City, TN 38261

Trade Name(s): Lennox Hearth Products

Product: Gas-fired vented decorative fireplace heaters
MEA Index #300-20 – Gas Fireplace

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.88-2005, Z21.88a-2007)

Laboratory: Omni-Test Laboratories, Inc.

Test Report(s): Report #116-F-32-5, issued May 9, 2005 and Report #116-F-29-5, issued May 9, 2005.

Description: Gas-fired, vented decorative fireplace heaters.

Model No.	Input: Natural Gas	Width of Unit
SDVST-N, SDVPPF-N	37,500	35" Nominal
SDV35-N	23,000	35" Nominal

Terms and Conditions: The above-described fireplace heaters are accepted for decorative heating operation under the following conditions:

1. Venting of the above equipment is subject to Section 27-879 of the New York City Building Code.
2. Units shall use natural gas only.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance August 14, 2008
Examined By Donald J. [Signature]