



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 419-06-E Vol. 2

Manufacturer: Spark Modern Fires, 53 Chestnut Woods Road, Redding, CT 06896

Trade Name(s): Fire Ribbon

Product: Gas-fired vented decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.88a)

Laboratory: Omni Test Laboratories Inc.

Test Report(s): 321-F04-5, dated September 20, 2007.

Description: Gas-fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No.	Maximum Input Rating (Btu/hr)	Minimum Input Rating (Btu/hr)
91N – See Through	38,000	27,000
92N – Peninsula	38,000	27,000
18N – 6 ft.	77,000	52,000

Terms and Conditions: The above-described gas-fired vented appliances are accepted under following conditions:

1. Units shall be fired by natural gas only.
2. Provide required combustion air and ventilation in accordance with the New York City Building Code, and in particular with Section 27-879.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 11/21/15

Examined By [Signature]