



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 42-98-E Vol.4

Manufacturer: Alliance Laundry Systems LLC, Shepard Street, P.O. Box 990, Ripon, Wisconsin 54971-0990

Trade Name(s): Unimac, Huebsch, Speed Queen, Ajax, Private Labeled Models

Product: Commercial Gas Clothes Dryers

Pertinent Code Section(s): 27-800, 27-807, RS 14-2 (ANSI Z223-1)

Prescribed Test(s): RS 14-6 (ANSI Z21.5)

Laboratory: CSA International

Test Report(s): 1059514, 1088665, 1088668, 1088671, 1195495, 1204290, 1204352, 1251142, 1273737, 1660226

Description: - Commercial, gas fired clothes dryers, designed for commercial and coin-operated usage. Variations include electro-mechanical and electronic controls. Unit consists of steel main burner, an intermittent ignition system comprising igniter with a sensor circuit and ignition control, combination gas pressure regulator and temperature controls. Units with model numbers and input ratings are listed below.

| Model Number | Input Heating Rate BTU/Hr | CSA International Report No. |
|-------------------------------------|---|---------------------------------|
| (AT, ST, HT, UT, MT, NT, YT, ZT)025 | 64,000 | 164789-1088665 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)030 | 73,000 | 164789-1088688 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)035 | 90,000 | 164789-1088671 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)T30 | 73,000 Per Pocket 146,000 Per Machine | 164789-1059514 |
| (AT, ST, HT, UT, MT, NT, YT, | 95,000 Per Pocket | 164789-1660226 |

| ZT)T45 | 190,000 Per Machine | |
|-------------------------------------|---------------------|----------------|
| (AT, ST, HT, UT, MT, NT, YT, ZT)050 | 120,000 | 164789-1195495 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)075 | 165,000 | 164789-1204290 |
| (AT, ST, HT, UT, NT, YT)F75 | 210,000 | 164789-1204352 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)120 | 300,000 | 164789-1251142 |
| (AT, ST, HT, UT, MT, NT, YT, ZT)170 | 395,000 | 164789-1273737 |

Notes: 1. Application and Installation Precautions may be installed on a combustible floor.

Application is suitable for water-washed fabrics only.

2. Clearance requirements

Top and sides – 0 inches; Rear – 24 inches minimum from back of dryer, 36 inches suggested for service; Front – 28 inches minimum for door opening.

Terms and Conditions: That the above described gas-fired clothes dryer, be accepted for use when fired by natural gas only. Provision for combustion air and ventilation air shall be made in accordance with Section 27-807 and other applicable code requirements. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped and delivered is equivalent to those tested and accepted for use, as provided in Section 27-131 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance May 11, 2006
 Examined By Simon Derkinderen