



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 420-92-E Vol. 2

Manufacturer: NIBCO Inc.
1516 Middlebury Street
Elkhart, IN 46515

Trade Name(s): NIBCO Inc.

Product: Gate valves

Pertinent Code Section(s): RS 17-6A

Prescribed Test(s): UL 262

Laboratory: Underwriters Laboratories Inc.

Test Report(s): File Ex2586, Projects 90NK4997, 98NK31534, 02NK32721, 07NK07804 and 07NK12999 issued May 10, 1990, revised October 16, 2007.

Description: UL listed, iron-body, bronze trim, OS&Y gate valve, **Model F697-0**, is designed for use as main shut-off valve in fire suppression systems. Valve has a rated maximum pressure of 350 psi wwp. Valve is available in sizes 2½" through 10".

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated June 3, 2008, F.P. Index #0805057).

Terms and Conditions: The above described OS&Y gate valve is accepted under the following conditions:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, Reference Standards 17-3 & 17-6A. Further, the installation shall be in accordance with the manufacturer's recommendations and UL standard 262.
2. Manufacturer's maintenance procedures and limitations shall be adhered to.
3. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
4. Periodic maintenance, test, and inspection shall be conducted in accordance with the regulations of Fire Department.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance June 19, 2008
Examined by Donald [Signature]