



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 421-06-E

Manufacturer: Lennox Industries, 512 W. Lennox Road, Stuttgart, Arkansas 72160

Trade Name(s): Lennox

Product: Single-packaged air conditioning units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): UL 1995

Laboratory: CSA International

Test Report(s): CSA Report No. 1668567, dated August 10, 2005

Description: Single-packaged cooling units designed for rooftop or outdoor installation and for use with ductwork connected to conditioned space. Cooling section employs refrigerant R-22. Cooling section is comprised of hermetically-sealed compressor, air-cooled condenser, evaporator coil with direct drive blower, expansion valve and safety controls. Units, with model numbers and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (Tons)
TCA036	3.0
TCA048	4.0
TCA060	5.0
TCA072	6.0

Terms and Conditions: The above-described packaged air conditioner units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use only Refrigerant R-22.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 2/14/07

Examined By Shyam. Patel