

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 423-00-E

Report of Material and Equipment Acceptance Division

Manufacturer- Glo-Fire Inc., 135 W. Sumner Street, Lake Elsinore, CA 92530.

Trade Name(s) - Glo-Fire.

Product - Gas fired decorative log appliance.

Pertinent Code Section(s) - 27-800.

Prescribed Test(s) -RS 14-6 (ANSI Z21.60a).

Laboratory - CSA International.

Test Report(s) - No. 113249-1, dated February 8, 1999.

Description - Gas fired decorative log appliance designed to provide supplemental heating and to enhance the aesthetic of a room. The logs are ceramic and are designed to be used in a vented fireplace. These are for use in wood burning fireplace. Their model numbers with their input ratings are listed below:

Model No.	Input Rating BTUH
GE-18	60,000
GE-24	72,000
GE-36	72,000
HP-18	60,000
HP-24	72,000
HP-30	72,000
MDX-18	60,000
MDX-24	72,000
MDX-30	72,000

Note: GE - Golden Ember; HP - Hampton; MDX - Manchester Deluxe

Recommendation - That the above described gas fired log appliance be accepted for use in vented fireplaces only, for decorative heating operation on natural gas and for indoor installation only with combustion air and required ventilation air provided. Venting of the fireplace is subject to Section 27-879 of the Building Code. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

2/14/01

Examined by

Stacy M. Givens