



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 427-91-E Vol.10

Manufacturer: SYSTEM SENSOR, UNICORPORATED DIVISION OF HONEYWELL INTERNATIONAL INC., 3825 OHIO AVENUE, ST. CHARLES, ILLINOIS 60174

Trade Name(s): SILENT KNIGHT

Product: FIRE ALARM EQUIPMENT

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89 BCR), SUBCHAPTER 17

Prescribed Test(s): UL 864

Laboratory: UNDERWRITERS LABORATORIES INC.

Test Report(s): MULTIPLE LISTING CORRELATION FILE NO. S3511, ISSUED MARCH 21, 2006.

System Sensor Model No.	Silent Knight Honeywell Co Model No	Description
ISO-X	IDP-ISO	Fault Isolator Module

Terms and Conditions: The above unit be accepted on condition that all uses, locations and installations shall comply with Article 17, Reference Standard 17 of New York City Building Code, the Electrical Code of The City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance June 27, 2006

Examined by Donald [Signature]