



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 427-91-E Vol. 11

Manufacturer: System Sensor, A Div. of Honeywell Int'l, 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Secutron

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17-3

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): ML File S6487 issued December 10, 1998 and revised November 7, 2005.

Description: Approval is requested for Secutron bases.

System Sensor	Secutron	Description
B501	MRI-B501	Base

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through 17-3C inclusive as applicable, including NFPA as appropriate, UL listing, the manufacturer's instructions, the Fire Department directives and the Electrical Code of the City of New York.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance July 17, 2007
Examined By Donald [Signature]