



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 428-05-M

Manufacturer: Bright Path Lighting, Inc., 3034 Tulare Street,
Fresno, CA 93721

Trade Name(s): BPL NY Series

Product: Non-skid photoluminescent signs and markings

Pertinent Code Section(s): Local Law 26, RS 6-1 and RS 6-1A

Prescribed Test(s):

1. Brightness Rating – ISO 17398:2004
2. Washability ASTM D 3648-2004
3. Toxicity Bombardier SMP 800-C
4. Radioactivity ASTM D 3648-2004
5. Flame Spread ASTM E 162-2002

Laboratory: Bodycote Materials Testing- Test 3
California Institute of Electronic and Materials
Science-
Tests 1, 4 & 5
DL Laboratories- Test 2

Test Report(s): California Institute of Electronics and Materials
Science Test Nos. 950401752-1-Oct. 25, 2005,
950401752-2-Oct. 25, 2005, 950401752-3-Oct. 25,
2005
Bodycote Materials Testing Canada Inc. –Report
No. 05-02-794(C)-Oct. 26, 2005
DL Laboratories- Test No. DL-14681-Nov. 9, 2005

Description: Items listed within are photoluminescent non-skid materials. This safety grade photoluminescent material is designed to meet requirements of RS6-1 and RS 6-1A NYC LL26

Item Description	Size (approx.)	Model No.
Non-Skid Tape, Peel & Stick, self adhesive	1"x25'	BPLNY312
Non-Skid Tape, Peel & Stick, self adhesive	1.5"x25'	BPLNY313
Non-Skid Tape, Peel & Stick, self adhesive	2"x25'	BPLNY314
Non-Skid Tape, Peel & Stick, self adhesive	Custom Size	BPLNY315*

Note: The model(s) with asterisks comply with laboratory tests but do not satisfy the design and/or dimensional requirements for mandatory installations under Section 2.1 and 2.2 of RS 6-1. These models with asterisks may be installed only as "additional signs and markings" under Section 2.5 of RS 6-1.

Terms and Conditions: That the above units are accepted on condition that:

1. Pathway markings of green color shall be in compliance with ANSI Z535.1 Safety Color Code.
2. Arrows and egress symbols shall comply with ISO 7010 E001, E002, E003 and E004.
3. All approved materials shall be labeled and identified with the model number as well as with MEA No. 428-05-M. BR: 32-8-5 in a minimum of six (6) point type with at least one such identification on each piece of material installed in accordance with RS 6-1.
4. No radioactive materials are to be used.
5. All signs and markings shall conform to the pictorial representations submitted with this application.
6. All models directing persons to exits are to be installed at a low-location so as not to confuse with other required exit signage.
7. That non additional transparent or translucent over-laminates, varnishes, or other coatings be applied to the photoluminescent portions of the marking.
8. This acceptance is limited to the materials use and does not include the installation for compliance with 27-383(b) and Reference Standard 61, which is the responsibility of the building owner.
9. All shipments and deliveries of photoluminescent exit path markings shall be provided with a certification from the manufacturer, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

Note: Per §27-131 (d), all materials tested and acceptable for use, shall be subject to periodic retesting as determined by the Commissioner; and any material which, upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to insure safety.

Final Acceptance June 29, 2008
 Examined by Sjim Dorkhedam