

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 43-04-E
Report of Material and Equipment Acceptance Division**

Manufacturer – Nor-lake Inc., 727 Second Street, Hudson, WI 54016.

Trade Name(s) – Nor-Lake.

Product – Milk Dispensers.

Pertinent Code Section(s) -27-771, 27-772.

Prescribed Test(s) - RS 14-6 (UL 471).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File SA3931 dated September 22, 2003, File SA 13060 dated September 29, 2003.

Description – Commercial beverage dispensers, as listed below. Unit comprises control box, expansion valve, compressor, either air or water cooled condenser, dryer, evaporators, water pump float valve and ice sensor probe. T-134a is the refrigerant used for the system.

Products Covered:

Dispenser – Model DR101.

Electrical Rating:

115V, 60 Hz, Phase 1.

Recommendation - That the above commercial dispenser be accepted under the following conditions:

- 1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.**

2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. All shipments and deliverers of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 2/25/04

Examined by Shyam M. Jaiswal