



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 430-05-E

Manufacturer: Hobart Bakery Systems/Baxter Mfg., 19220 SR 162 East, Orting, WA 98360

Trade Name(s): Hobart/Baxter

Product: Electric rack oven

Pertinent Code Section(s): 27-787, 27-792

Prescribed Test(s): RS 14-6 (UL 197)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File E66035, dated January 30, 2003, revised June 17, 2006

Description: Electric rack-style oven for baked goods. Unit, with model numbers, are listed below:

Model No.	Description
BXA1E, BXA2E, HBA1E, HBA2E	Rack oven
HO300E	Mini rack oven

Electrical Ratings
208Vac, 240Vac

Terms and Conditions: The above electric commercial oven units are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Approval of all electrical equipment apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/30/07

Examined By Shyams, A