



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 434-04-E Vol. 2

Manufacturer: Electrolux professional S.P.A. Via Primo (Pordenone)
 Maggio 2 Violotta Di Chinos, Italy

Trade Name(s): Electrolux Professional S.P.A.

Product: Commercial Refrigerators and Freezers

Pertinent Code Section(s): 27-777, 27-772

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Intertek Testing Services NA Inc.

Test Report(s): No. 10427041 Dated, 8/3/04 Revised 8/10/05

Description: Commercial refrigerators and freezers for use in food service establishments. Units comprise on/off switches, refrigeration controllers, condensing, outlet boxes and junction boxes, refrigerant dryers, evaporators, and evaporator fans. Condensing units are equipped with compressors, starting capacitors, condenser, condenser fans, interior lighting, fan motors, and receivers. Evaporators are thermostatically controlled. R-22 is the refrigerant used for the system.

Product Covered:

- 9VTX 726377
- 9VTX 726674
- 9VTX 726378

Electrical Ratings:

Product No.	Voltage	Current	Frequency	Low Side Pressure	High Side Pressure
9VTX 726377	120 V	8 A	60 Hz	90 PSIG.	330 PSIG.
9VTX 726674	120 V	8A	60 Hz	90 PSIG.	330 PSIG.
9VTX 726378	120 V	7.1 A	60 Hz	88 PSIG.	203 PSIG.

Terms and Conditions: That the above commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of New York City Building Code.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 2/1/06

Examined by Sayans. Ahmed