



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 439-05-E

Manufacturer: International Refrigeration Products, 9517-P Monroe Road, Charlotte, NC 28270

Trade Name(s): NCP

Product: Portable air conditioners

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 14-6 (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA10632 dated February 10, 2005.

Description: Water- or air-cooled portable air conditioners designed for indoor installation. R-22 is the refrigerant used for the system. Each unit is comprised of an air- or water-cooled condenser and safety controls. Units, with model numbers and nominal cooling capacities, are listed below:

Model No.	Operation	Mfr's. Specified Nominal Cooling Capacity (BTU/H)
S115A-10K10	Cool only	9,500
S240A-13K11	Cool only	12,500
S240A-19K10	Cool only	18,500
S240A-22K10	Cool only	21,500
S115HP-10K10	Heat/Cool	9,500
S240HP-13K11	Heat/Cool	12,500
S240HP-19K10	Heat/Cool	18,500
S240HP-22K10	Heat/Cool	21,500

Terms and Conditions: The above-described portable air-conditioners are accepted under the following conditions:

1. Units shall use Refrigerant R-22 only.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 8/10/07

Examined By 