



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 439-06-M

Manufacturer: Neptune Products, Inc., 6835, rue Picard, St. Hyacinthe, Quebec, Canada J2S 1H3

Trade Name(s): Neptune

Product: Acrylic tubs and surround for interior finish acceptance

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: CSA International
 Bodycote Material Testing Canada Inc.
 Anderson Laboratories, Inc.

Test Report(s):

1. Bodycote Canada Inc., Project #04-02-849, dated December 14, 2004
2. Anderson Laboratories, Inc., Test #642, dated June 26, 2006

Description: Plastic material with a resin and fiber backing, 3/16" thick.

Catalogue Description	Size (inches – approx.)
Acrylic bathtubs, deck mount or alcove	30" x 60" x 21"
	32" x 60" x 21"
	34" x 66" x 21"
	36" x 66" x 21"

Flame Spread Rating – 195 Smoke Developed Rating – 350

Note:

Upon exposure to fire, the material does not produce products of decomposition or combustion that are more toxic than those given off by wood or paper when decomposing or burning under comparable conditions.

Terms and Conditions: The above-described fiberglass-reinforced acrylic bathtubs and surround with Class C flame-spread rating are accepted for interior finish approval with the following conditions:

1. Materials having a smoke-developed rating of 350 shall not be used in exits or corridors, in institutional occupancies or in rooms where the net floor per occupant is ten square feet or less.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. Installation of tubs and associated plumbing must be in accordance with Reference Standard RS 16.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance October 12, 2006

Examined By Srin Derphala