

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 44-07-E

Manufacturer:	Kinco Food Service Equipment, 248 Bowery Street, New York, N.Y. 10012
Trade Name(s):	Kinco Ovens
Product:	Electric ovens
Pertinent Code Section(s):	27-777(d), 27-787, 27-792
Prescribed Test(s):	RS 14-6 (UL 197)
Laboratory:	Intertek ETL Semko
Test Report(s):	No. 3106958NYM-002

Description: The units are electric deck ovens which are available in single-, double- or triple-stacked configuration.

Product Covered

Deck Bakery Ovens – CH-GP36E 1D, CH-GP36E 2D, CH-GP36E 3D, CH-3P36ES 1D, CH-GP36ES 2D and CH-GP36ES 3D.

Model Similarity

Models CH-GP36E 1D, CH-GP36E 2D, CH-GP36E 3D are similar to CH-GP36ES 1D, CH-GP36ES 2D and CH-GP36ES 3D except for the optional steam injector module and digital displays.

Electrical Ratings

	Voltage	Current	Frequency
CH-GP36E 1D, CH-GP36E 2D,			
CH-GP36E 3D, and CH-GP36ES 1D,	208/220Y V 3Φ	46.8A	60Hz
CH-GP36ES 2D, CHGP36ES 3D			
CH-GP36E 1D, CH-GP36E 2D,			
CH-GP36E 3D, and CH-GP36ES 1D,	208/220V -1 Phase	82.0A	60Hz
CH-GP36ES 2D, CHGP36ES 3D			

Terms and Conditions: The above electric deck ovens are accepted under the following conditions:

- 1. Units shall be installed in accordance with manufacturer's instructions and the New York City Building, Electrical and Fire codes requirements.
- 2. Cooking equipment shall be installed under hoods that vent to the outside and shall comply with Reference Standard RS 13 requirements of the New York City Building Code, and shall have a fire-suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and capable of simultaneous discharge and manual release. The fire-suppression system, exclusively used for cooking equipment, shall be filed with the Buildings Department and examined and approved by the Fire Department.
- 3. Adequate supply of fresh air for unit ventilation requirement shall be provided into room or space enclosing equipment.
- 4. The installation shall not obstruct access for operation and servicing.
- 5. For grease removal, suitable baffle type grease filters, MEA-approved, shall be installed.
- 6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
- 7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
- 8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance _____

Examined By _____