



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 440-05-E

Manufacturer: FPI Fireplace Products International Ltd., 6988
 Venture Street, Delta, British Columbia V4G 1H4

Trade Name(s): Regency, Hampton, Dell-Point

Product: Factory-built, wood-burning fireplaces

Pertinent Code Section(s): 27-848

Prescribed Test(s): RS 14-21 (UL1482), RS 14-20 (UL 127)

Laboratory: Omni Test Laboratories

Test Report(s): See Below

Description: Factory-built, wood-burning fireplaces.

Material /Equipment Trade Name	Sections of Law Pertinent to Use of Materials/Equipment	Individual Products	Model No.	Test Report	Description
Regency	UL 127/ULC S610	FP90	FP90	219-S10-2 (Feb. 2005)	Wood Fireplace
Hampton	UL 1482-1996/ ULC S628-1993	HI300	HI300	219-S-03-2 (Feb. 2003)	Wood Cast Insert
Hampton	UL 1482-1996/ ULC S627-2000	H200	H200	219-S-09-2 (Sept. 2005)	Freestanding Wood Stove
Dell-Point	ASTM E 1509-1995/ ULC C1482-M1990	Europa 75	Europa 75	120-S-01-2 (Apr. 1999)	Pellet Stove

Terms and Conditions: The above-described factory built, wood-burning fireplaces are accepted for supplemental heating and decorative purposes under the following conditions:

1. Units are wood-burning only fireplaces.
2. The installation shall be in accordance with listing laboratories specifications, manufacturer's supplied instructions and Section 27-848 of the New York City Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code.
3. Clearances to combustible construction shall be in accordance with RS 14-16 of the New York City Building Code.
4. All shipments and deliveries of such equipment shall be provided with a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance 7/26/2006

Examined by *Jayant Prasad*