



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### **MEA 454-06-E**

**Manufacturer:** System Sensor, Unincorporated Division of Honeywell International, Inc., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** System Sensor

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** RS 17-3, RS 17-13 and RS 17-14

**Prescribed Test(s):** UL 2075

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** E307195, Project No. 06CA13175, Vol. 1, Section 1, issued August 2, 2006

**Description:** Carbon Monoxide Detector – Model #CO1224

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 19, 2006, F.P. Index #0608019A.

**Terms and Conditions:** The above-described equipment is accepted provided that:

1. All uses, configurations, arrangements and functions, application and installations comply with all applicable provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 and RS 17-14.
2. Installation and spacing shall be in accordance with 1RCNY §28-02, manufacturer's recommendation, and UL standard.

3. All audible signaling devices shall have a distinct sound for carbon monoxide gas alarm from any fire alarm produced by the fire alarm system.
4. The above-referenced detectors shall be used only with listed and approved/accepted control panels and accessories.
5. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
6. Manufacturer's maintenance, testing procedures and limitations shall be complied with.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance October 2, 2006  
Examined By Donald Hill