



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 454-91-E Vol. 10

Manufacturer: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721

Trade Name(s): Fenwal®, Kidde®

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 through 27-977, Reference Standard RS 17

Prescribed Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S3743, Vol. 2, Section 3, issued December 12, 2006 and revised May 16, 2007.

Description: Model 70-200200-003 is an addressable signal/sounder module, which is an intelligent field device that provides standard notification or audio output. Connection to fire alarm control panel is via the signaling line circuit of the control unit mother board.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 11, 2007, F.P. Index #0707035A.

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17. Further, the installation and use shall be in accordance with manufacturer's recommendations, NFPA 72 and UL Standard.
2. The above models shall be used only with MEA-approved fire alarm equipment and accessories.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance October 16, 2007.
Examined By Donald [Signature]