



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 457-99-E Vol. 4

Manufacturer: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name(s): Honeywell.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): RS 17, Subchapter 17.

Test(s): UL 864.

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL Multiple Listing Fire No. S470, issued April 15, 2005.

Description – Fire Alarm Equipment as listed below:

System Sensor Model No.	Honeywell Model No.	Description
FMM-1	XLS-MM-A	Control Modules
FMM-101	XLS-MM-B	Control Modules
FZM-1	XLS-MM-Z	Control Modules
FCM-1	XLS-CM-N	Control Modules
FRM-1	XLS-CM-R	Control Modules
FTM-1	XLS-CM-T	Fire Phone Module

Terms and Conditions: That the above equipment be accepted provided that all uses, locations, and installations shall comply with Article 17, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance June 1, 2006

Examined by [Signature]