

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 46-05-E

Report of Material and Equipment Acceptance Division

Manufacturer – Lenox Hearth Products, 111 W. Taft Avenue, Orange, CA 92185.

Trade Name – Lenox Hearth Products.

Product – Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.88).

Laboratory – Omni-Test Laboratories Inc.

Test Report– No. 116-F-02-5 dated January 13, 2005.

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No.	Description	Rating BTUH
LSS-35C	Direct vent fireplace with standing millivolt ignition system, variable speed blower Integrated wireless remote control with thermostatic operation.	33,000
LSS-40C		41,500

Recommendation - That the above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electric equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 3/30/05

Examined By [Signature]