



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 461-06-E

Manufacturer: York International, Unitary Products Group,
P.O. Box 19014, Wichita, KS 67204-9014

Trade Name(s): York, Luxaire, Coleman, Non-Branded

Product: Air handlers and coils

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 14-6 (UL 1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): SA3483, Vol. 4, Section 1, Project 05SC05972,
issued December 9, 2005, revised August 30, 2006

Description: Indoor sections for York International split-system air conditioners and heat pumps. These sections consist of single unit blower coils or are also available as individual blower or coil components. These components provide indoor air circulation and system-matched refrigeration coils, used for either heating or cooling, depending on outdoor system utilized, AC or heat pump.

Product Covered:

(A,S)(HP, VG, VY, VC, VL)(18,24,30,36,42,48,60)(A,B,C,D)(4,3,2,-)(A,B,C,X)(H,N)(1,2,3,4)#(A,B,C,D,E,F,G,H,J,K,L,-)*
(MA,MV)(08,12,16,20)(B,C,D)N(2,3,4)#(A,B,C,D,E,F,G,H,J,K,L,-)*
(UC,PC,FC,MC,HC,HD,MH)(24,30,36,42,60)(A,B,C,D,S,Q)(4,3,2)(A,B,C,X)(H,N)#*

Terms and Conditions: The above-described air handler and coil units are accepted under the following conditions:

1. Units shall be installed indoors.
2. Units shall use Refrigerant R-22 only.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 7/25/07

Examined By [Signature]