



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 463-06-E

Manufacturer: Perlick Corporation, 8300 W. Good Hope Road, Milwaukee, WI 53223

Trade Name(s): Perlick

Product: Commercial refrigerators and freezers (self-contained)

Pertinent Code Section(s): 27-771, 27-772, 27-777(f)

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA2110, dated May 20, 1996, revised February 19, 2006

Description: Commercial refrigerators and freezers (self-contained), as tabulated below, are for cooling bulk beverages. Units are intended for indoor use and for free-standing installation. Units are comprised of on/off switches, condensers, interconnecting refrigerant lines and evaporators. Evaporator is combined with a fan motor, drain opening and mechanical-type expansion valve or capillary tube. Types of refrigerants used for these units are R-134A.

Product Covered

Self-contained back bar coolers	BS32, BS60, BS84, BS108, CS32, CS60, CS84, CS108, NS52, NS72, PS60, PS84
Self-contained beer dispensers	DS32, DP32, DS60, DS72, DS84, DC72, DC84, DC96

Terms and Conditions: The above commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall only use Refrigerant R-134A.
2. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
3. Adequate supply of fresh air for ventilation shall be provided into room or space enclosing equipment.
4. The installation shall not interfere with accessibility for operation and servicing.
5. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
7. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
8. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 11/9/06

Examined By Stephen Marx