



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 47-07-E

**Manufacturer:** Simon-Aire Inc., 745 East 9<sup>th</sup> Street, New York, N.Y. 10009

**Trade Name(s):** Simon-Aire

**Product:** Packaged terminal air conditioner units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11 (UL 1995)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA32206, dated January 16, 2007

**Description:** Packaged terminal air conditioner units, designed for indoor installation. R-22 is the refrigerant used for the units. The chassis are cord-connected thru-the-wall package terminal air conditioners used to cool a single room. The system is comprised of compressor, air-cooled condenser coil with fan and evaporator coil with a blower. Units, with model numbers and cooling capacities, are listed below:

Model No.	Cooling Capacity, Tons
SSK509	.80
SSK513	1
SSK816	1.34
SSK818	1.36
SSZ509	.80
SSZ513	1
SSZ816	1.34
SSZ818	1.36

Model No.	Cooling Capacity, Tons
SSCT509	.80
SSCT513	1
SSCT816	1.34
SSCT818	1.36
SSNS509	.80
SSNS513	1
SSNS816	1.34
SSNS818	1.36
SSEA509	.80
SSEA513	1
SSEA816	1.34
SSEA818	1.36

**Terms and Conditions:** The above-described packaged air conditioner units are accepted for indoor installation, under the following conditions:

1. Units shall use only Refrigerant R-22.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 3/29/07

Examined By Shyam. P

