



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 478-06-E

Manufacturer: American Gas Log, LLC, 5051 Snapfinger Woods Drive, Decatur, GA 30035

Trade Name(s): Best Fire

Product: Gas-fired decorative log appliance

Pertinent Code Section(s): 27-800, 27-826

Prescribed Test(s): RS 14-6 (ANSI Z21.60a)

Laboratory: Omni Test Laboratories

Test Report(s): No. 324-L-04-4, dated May 19, 2006

Description: Gas-fired decorative log appliance designed to provide supplemental heating and to enhance the aesthetics of a room. The logs are designed to be used in a vented fireplace.

Product Covered:

- | | |
|----------------------------------|----------------------------|
| EV – Eastern Vine | HHTRW – Real Wood |
| HO – Highland Charred Oak | HHTVW – Versa Wood |
| SROD – Split Rustic Oak Designer | HHTSO – Supreme Oak |
| SRO – Split Rustic Oak | AOSS – American Split Oak |
| CFS – Campfire | TO – Texas Oak |
| WF – Wildfire | AP – American Pecan |
| AO – American Oak | GH – Grand Hollow |
| AOS – American Oak Designer | HCO – Highland Charred Oak |
| SMO – Split Mountain Oak | SC – Split Chestnut |
| BI – Blazing Inferno | TCO – Texas Charred Oak |
| CM – Country Manor | B – Birch |
| LC – Log Cabin | GMO – Grand Massive Oak |
| CO – Charred Oak | GO – Golden Oak |
- CH – Charred Hickory

Terms and Conditions: The above-described gas-fired log appliance is accepted for decorative heating operation under the following conditions:

1. Heating operation shall use natural gas only.
2. Units shall be operated in vented fireplaces only; this is subject to Section 27-879 of the New York City Building Code.
3. Units shall be installed indoors only, with combustion air and required ventilation air provided.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/23/07

Examined By 