

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 49-02-E
Report Materials and Equipment Acceptance Division**

Manufacturer – Krack Corporation, 401 South Rolwing Road, Addition, IL 60101.

Trade Name – Krack.

Product – Refrigeration unit cooler.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Tests – RS 13-11(UL 1995).

Laboratory - Underwriters Laboratories Inc.

Test Report – File SA2917 dated April 24, 1978, revised March 23, 1993.

Description – These units are intended for installation and *refrigeration systems employing refrigerant 12, 22, 404A, 502 *R507 or R-717. The working pressure for these devices is a *minimum of 180 psig. Units, consist of a fan motor, fan and evaporator coil and drain pan.

PRODUCT COVERED:

Unit coolers Models BTR with or without Suffix "C" followed by -11, -21, -31, or -41 followed by -4, -6, or -8, followed by -DX, -RT, -RB or -FL followed by -F12, F22, F502 or followed by -A, - HGC, WD - HGU, may be followed by additional suffixes.

TYPE OF DEFROST:

A-Air, HG-Hot gas unit and drain pan, *WD - water defrost.

Note: * - Not employed on models with copper tube evaporator.

Recommendation - That the above described unit cooler, be accepted, under the following conditions:

1. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 6/10/02

Examined by Shyam M. Das