

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 49-03-E
Report of Material and Equipment Acceptance Division

Manufacturer – Simplex Time Recorder Co., 100 Simplex Drive, Westminster, MA 01441.

Trade Name –Ansul.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) –Reference Standard RS-17.

Test –UL 864.

Laboratory – Underwriters Laboratories, Inc.

Test Reports – File S771, Vol. 52, Sec. 1, Assignment 01NK42204, dated May 14, 2002; File S771, Vol. 53, Sec. 1, Assignment 02NK2887, dated May 3, 2002, revised January 10, 2003; file S771, Vol. 54, Sec. 1, Assignment 02NK2887, dated May 6, 2002; and Multiple Listing File No. S4935, issued October 16, 2002 and revised November 26, 2002.

Description – Fire Alarm Equipment as follows:

Model	Product
The following products are found in UL File S771, Vol. 52, Sec. 1, 5-14-02 and have been evaluated to Standard UL 864.	
4004-9301	Four Zone Local Fire Alarm Control Unit suitable for Releasing Device Service, rated 120 to 240 Volts AC Input – Beige Enclosure
4004-9302	Four Zone Local Fire Alarm Control Unit suitable for Releasing Device Service, rated 120 to 240 Volts AC Input – Red Enclosure
The following products are found in UL File S771, Vol. 53, Sec. 1, 5-3-02 and have been evaluated to Standard UL 864.	
4090-9005	Addressable Releasing Device Circuit Module
4090-9006	Addressable Releasing Device Circuit Module mounted in an Enclosure wit Red LED on the front door.
The following products are found in UL File S771, Vol. 54, Sec. 1, 5-6-02 and have been evaluated to Standard UL 864.	
4090-9812	Optional Red LED with wire harness for use with Model 4090-9005 Module
2975-9227	Red Enclosure for mounting of 4090-9005 Module

Basic Applicant's (Supplier's) Product Designation	Multiple Listee's Product Designation
4004-9302	Autopluse Z-10 (430525)

Pursuant to "Promulgation of the Rules relating to Materials and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated March 5, 2003, F.P. Index #0302055.

Recommendation- That the above units be accepted on condition that:

All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

March 23 2004

Examined by