



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 493-06-E

**Manufacturer:** Giacomini S.p.A., Via per Alzo, 39, 28017, San Maurizio D'Opaglio (No), Italy

**Trade Name(s):** Giacomini

**Product:** Fire Department connections

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS 17

**Prescribed Test(s):** UL 405

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File Ex3314, Project 05NK10153, issued April 4, 2006. UL letter dated July 20, 2006

**Description:** Fire Department connections - Double clapper two-way inlets.

Model No.	Description	Size
A105	Straight double clapper two-way inlets	3" x 3" x 4" – rated 300 psig.
A106	90° double clapper two-way inlets	3" x 3" x 4" – rated 300 psig.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated September 20, 2006, F.P. Index #0609007.

**Terms and Conditions:** The above units are accepted on condition that:

1. Installation shall comply with all applicable New York City codes, rules, regulations and testing requirements and in particular with the requirements of Title 27, Subchapter 17, Article 3 §27-951 and RS 17-3 of the Administrative Code.
2. The Siamese connection, when installed, shall be subject to a hydrostatic pressure test of at least 300 psig for at least one hour.
3. UL listing requirements and limitations shall be complied with.
4. Manufacturer's installation, maintenance and limitations shall be complied with.
5. The conditions of approval shall be enumerated in the installation manuals and sales brochures that will be provided to all New York City buyers, users and installers.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 29, 2007  
Examined By Donald [Signature]