



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 506-06-E

Manufacturer: Anvil America Inc., 5535A NW 35th Avenue, Fort Lauderdale, FL 33309

Trade Name(s): ANVIL

Product: Commercial gas-fired griddles and broilers

Pertinent Code Section(s): 27-800, 27-826, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.11)

Laboratory: CSA International

Test Report(s): No. 208714-1759094 and No. 208714-1759101, dated December 2006

Description: Commercial gas-fired griddles and broilers as listed below. Each unit is comprised of a main burner, and is manually-controlled.

Model No.	Rating (BTUH)
FTG9012	1 @ 28,000
FTG9016	1 @ 28,000
FTG9024	2 @ 56,000
FTG9036	3 @ 84,000
(CBR, CBL) 9012	1 @ 28,000
(CBR, CBL) 9016	1 @ 28,000
(CBR, CBL) 9024	2 @ 56,000
(CBR, CBL) 9036	3 @ 84,000

Terms and Conditions: The above commercial gas-fired griddles and broilers are accepted under the following conditions:

1. Units shall use natural gas only.
2. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical, Building and Fire Codes requirements.
3. Minimum installed clearance from combustible construction shall be in accordance with RS14-15 of the New York City Building Code.
4. Cooking equipment shall be installed under hoods that vent to the outside, comply with Reference Standard RS-13 requirements of the New York City Building Code, have a fire suppression system complying with Reference Standards RS 13-2 and RS 13-3 with open heads and be capable of simultaneous discharge and manual release. The fire suppression system exclusively used for cooking equipment shall be filed with the Building Department and examined and approved by the Fire Department.
5. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
6. The installation shall not interfere with accessibility for operation and servicing.
7. For grease removal, suitable baffle type grease filters, MEA-accepted, shall be installed.
8. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
9. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
10. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance

2/16/07

Examined By

Suyani Prasad