



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 521-06-M

Manufacturer: MVP Group, 5201 260th Street, Wyoming, MN 55092

Trade Name(s): MVP Group/Rum River Doors & Millwork
Midwest Veneer & Pressing

Product: Fire-rated interior doors & interior frames

Pertinent Code Section(s): 27-329, 27-342

Prescribed Test(s): RS 5-6 (ASTM E-152, UL 10C)

Laboratory: Intertek Testing Services and Orfield Laboratories, Inc.

Test Report(s): ITS 20-90 Flush Fire Doors PP (12489)
ITS 20-90 Firestop Door Frame (13199)
Orfield Labs STC (OL 06-0601)

Description: Fire-rated 1¾" mineral-core doors and fire-rated door frames, utilizing core component that are manufactured by Georgia Pacific and limited to approved fire-rated hardware as described below:

Doors:

Model #	Rating	Singles	Pairs	
FD-5-45 PP	45 Min.	4'0"x9'0"	8'0"x9'0"	
FD-5-60 PP	60 Min.	4'0"x9'0"	8'0"x9'0"	
FD-5-90 PP	90 Min.	4'0"x9'0"	8'0"x9'0"	*STC36

Frames:

Model #	Rating	Singles	Pairs
FF-45 PP	45 Min.	4'0"x9'0"	8'0"x9'0"
FF-60 PP	45 Min.	4'0"x9'0"	8'0"x9'0"
FF-90 PP	45 Min.	4'0"x9'0"	8'0"x9'0"

***Note:** The doors shall be in compliance to and made in accordance with the authorized Listing Report, including the Manufacturing & Machining Specifications, and under conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to Multiple Listee Model(s) identified on the correlation pages of the Listing Reports.

Terms and Conditions: The above-described fire-rated doors and frames are accepted for Class "C" rating with the following conditions:

1. Doors shall be operated by an approved-fusible link or other New York City-approved automatic closing mechanism.
2. Doors shall be installed in accordance with Laboratory limitation, Manufacturer instructions and Reference Standard RS 5-8 (NFPA 80) for Class B or C openings.
3. Certificates or labels accompanying all shipments shall be provided by the testing service which shall be regularly engaged by the manufacturer to make periodic inspections and/or tests of the doors in the course of their manufacture.
4. All shipments and deliveries of such materials shall, in addition, be accompanied by a metal tag certifying that the materials shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance December 1, 2006

Examined By Simon Deshpande