



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 522-06-E

Manufacturer: American Standard Water Heater Corporation
12910 Mulberry Drive, Whittier, California 90605

Trade Name(s): American Standard, Duraglass

Product: Residential electric water heaters

Pertinent Code Section(s): 27-787

Prescribed Test(s): RS 14-6 (UL 174)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File E169649, dated January 18, 2000 and October 28, 1999.

Description: Electric storage-type water heaters designed for residential installation. Unit is comprised of a glass-lined water storage tank covered by foam insulation, immersion-heating element(s) up to 54 kW, thermostat and manual reset temperature-limiting device. Units are provided with means for permanent connection to electrical supply and to water supply, and opening for installation of temperature- and pressure-relief valve. Units, with model numbers and storage capacities, are listed below:

Model No.	Storage Capacity (Gallons)
CE-52 AS	52
CE-80 AS	80
CE-120 AS	120
CE-120 ASME	120

Terms and Conditions: The above-described electric water heaters are accepted under the following conditions:

1. Units may be installed on combustibile flooring. Minimum installed clearances from combustibile construction shall be in accordance with RS 14-15 of the New York City Building Code.
2. Automatic ASME-listed temperature- and pressure-relief valve, properly sized for heater and MEA-accepted, shall be furnished for heater installation.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance Nov. 21, 2007

Examined By Siun Derkudin