



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 530-06-E

Manufacturer: International Comfort Products, LLC, 7310 West Morris Street, Indianapolis, Indiana 46231

Trade Name(s): QuietComfort DLX 95

Product: Upflow horizontal gas furnace

Pertinent Code Section(s): 27-800, 27-825, 27-886, RS14-2 (ANSI Z223.1)

Prescribed Test(s): RS14-6 (ANSI Z21.47)

Laboratory: CSA International

Test Report(s): CSA File 157229-1167770 dated March 12, 2007

Description: Upflow/horizontal gas-fired, forced-air furnaces, model (C,H,T)9UHX, designed for indoor installation. Each unit is comprised of an induced draft assembly, PSC blower, main burner, aluminized steel heat exchanger assembly, and a hot surface ignition system comprised of an igniter, flame sensor and two-stage combination gas-pressure regulator. Units are provided with temperature-limit controls. Units, with model numbers and input heating ratings, are listed below:

Model Number	Input Heating Rating (BTUH)
(C,H,T)9UHX060F12	60,000
(C,H,T)9UHX080J12	80,000
(C,H,T)9UHX080J16	80,000
(C,H,T)9UHX100L20	100,000

Note:

C = Comfortmaker, T = Tempstar, H = Heil/Arcoaire

Terms and Conditions: The above-described upflow, forced-air furnaces are accepted under the following conditions:

1. Units may be installed on combustible flooring. Minimum installed clearances from combustible construction shall be as follows: Top – 1 inch; front – 3 inches; rear – 1 inch; sides – 1 inch each; front clearance for service – 30 inches.
2. Units shall be installed indoors only.
3. Units shall be fired on natural gas only.
4. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutters within the system that shall be constructed or controlled so as to prevent the closure beyond 80 percent of the gross duct area at all times.
5. If furnace is installed in combination with a cooling system, then cooling system must be MEA-accepted.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptances August 17, 2007.
Examined By Sun Derkhdan