



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 559-06-M

**Manufacturer:** Milliken Wall Fabrics, 1000 Elm Street, LaGrange, GA 30240

**Trade Name(s):** 180 Walls

**Product:** Wall-covering material

**Pertinent Code Section(s):** 27-348

**Prescribed Test(s):** RS 5-5 (ASTM E84), Toxicity

**Laboratory:** Commercial Testing Company (CTC)  
Anderson Laboratories, Inc. (AL)

**Test Report(s):** CTC Report Nos. 3772-0502 dated April 28, 2006, 07-01266 dated January 15, 2007, 0701398 dated January 26, 2007, 0701397 dated January 26, 2007, 070126(3,4) dated January 15, 2007 and AL No. 643 dated June 26, 2006

**Description:** Wall-covering material, 180 Walls™ collection, is wall fabric with a pressure-sensitive adhesive on the back surface for quick installation. The fabric contains Stain Smart™ and antimicrobial additive. The material is woven Jacquard with fiber content of 100% post-industrial polyester with total weight of 15.5 ± .5 ounces per linear yard.

Upon exposure to fire, the product does not create products of decomposition or combustion that are more toxic than those given off by wood or paper when decomposing or burning under comparable conditions.

Model No.	Flame Spread Rating	Smoke Developed Rating
<b>Bari 5118</b>	<b>20</b>	<b>85</b>
<b>Lario 5115</b>	<b>25</b>	<b>50</b>
<b>Riviera 5116</b>	<b>25</b>	<b>65</b>
<b>Seine 5114</b>	<b>20</b>	<b>80</b>
<b>Varenna 5117</b>	<b>25</b>	<b>65</b>

**Terms and Conditions:** The above-described wall-covering material is accepted with the following conditions:

1. Material is for interior-finish with Class A flame spread rating, as indicated.
2. Material shall not be used in exits, corridors or in Occupancy Group H-1 or H-2.
3. All shipments and deliveries of such material shall be provided with a label suitably placed, certifying that the material shipped or delivered is equivalent to that tested and is acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance 4/3/07

Examined By Simon Durbidjan dfr.