



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 56-07-M

Manufacturer: Temple-Inland

Trade Name(s): TemStock - FR

Product: Fire-resistant wood particleboard

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E 84), Toxicity

Laboratory: Underwriters Laboratories, Inc. – ASTM E 84
Southwest Research Institute (SWRI) – Toxicity

Test Report(s): UL Project #R21867 dated January 18, 2005 and
SWRI Project #01.12696.02.038 dated May 31, 2007.

Description: Fire-resistant wood particleboard panel designed for general construction for interior-finish applications. The board will be 3/8" to 1" in thickness with varying width and length

Flame Spread Rating – 20
Smoke Developed Rating – 35

Notes:

- 1) Panels may be cut without affecting the surface-burning characteristics of the product.
- 2) Boards shall be used in a manner consistent with uses for industrial grade particleboard in conformance with ANSI A208.1, Table A. The board is not intended for structural applications.
- 3) Bundle of approved material shall be labeled, "TemStock – FR".

Terms and Conditions: The above-described particleboard is accepted with the following conditions.

1. Material is suitable for interior-finish with Class 'A' flame spread rating, as indicated above.
2. Material with smoke density greater than 25 shall not be used in exits or corridors.
3. All shipments and deliveries of such materials shall be provided with a label, suitably placed, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance August 9, 2007

Examined By Simon Derphidan