



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 575-06-M

Manufacturer: Conquest AccessAbility Inc., 2150A Drew Road,
Mississauga, Ontario L5S 1B1 CANADA

Trade Name(s): "CQ" -Lock

Product: Landing door or gate interlock for private residence
elevators and wheelchair platform lifts

Pertinent Code Section(s): 27-990

Prescribed Test(s): RS 18-1 (ANSI A17.1), UL 104

Laboratory: Canadian Standards Association (CSA)

Test Report(s): CSA Project Number 1742092, dated September 9,
2006.

Description: A swing door or gate electro-mechanical locking device for private residence elevators or wheelchair platform lifts comprising of a frame-mounted stainless-steel fabricated body, low-voltage electrical solenoid, stainless-steel locking shutter(box), electrical wiring; electrical contacts and contact block, PCB with connection terminals, reed switch, lock cover and fastening screw. A separate door mounted, keeper or beak assembly is provided c/w a permanent magnet.

Terms and Conditions: The above described electro-mechanical door locking device is accepted with the following conditions:

1. Units shall be installed and adjusted as per manufacturer's instructions, subject to the approval of elevator inspection department at the installation site.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance October 23, 2009

Examined By Simon Derphudam