



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 580-06-E Vol. 2

Manufacturer: Gentex Corporation, 10985 Chicago Drive, Zeeland, MI 49464

Trade Name(s): Gentex

Product: Speakers for fire-protective signaling systems

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS-17

Prescribed Test(s): UL 1480 and UL 2043

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File S5182, Project 01NK40776, dated January 30, 2002, revised April 3, 2006

Description: Speakers for fire-protective signaling systems.

Model #SSPKCLPR is a fire alarm speaker with red faceplate, listed for 25 and 70.7 Volt, with 1/8 to 4 Watt taps.

Model #SSPKCLPW is a fire alarm speaker with white faceplate, listed for 25 and 70.7 Volt, with 1/8 to 4 Watt taps.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated February 5, 2007, F.P. Index #0701035.

Terms and Conditions:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and with Reference Standards 17-3 through 17-5, the Electrical Code of the City of New York and applicable Fire Prevention Directives.
2. The installation of units shall be in accordance with the manufacturer's recommendation and UL test report, File S5182.
3. The above units shall be used only with MEA-approved control panels and accessories with which the compatibility has been determined to be acceptable by the Engineer of Record or a UL test report.
4. UL and manufacturer's maintenance procedures and limitations shall be complied with.
5. Unit shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 8, 2007
Examined By Donald [Signature]

