



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 585-06-E

Manufacturer: Lennox Hearth Products, 1110 West Taft Avenue, Orange, CA 92865

Trade Name(s): Lennox

Product: Factory-built, wood-burning fireplace

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z21.88a-1998)

Laboratory: Intertek Testing Services

Test Report(s): No. 3074084, dated May 19, 2005.

Description: Gas-fired, decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. Model with input rating is listed below:

Model Name	Input Rating (BTUH)
Montecito/BIS Tradition CE	80,000

Terms and Conditions: The above-described gas-fired, vented appliance is accepted for decorative heating operation with the following conditions:

1. Unit shall use natural gas only.
2. Unit shall be installed indoors only with combustibile air and required ventilation provided.
3. Venting of unit is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance

7/25/07

Examined By

Stuyvesant - [Signature]