



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 590-06-E

Manufacturer: Carrier Corporation, 7310 West Morris Street, Indianapolis, Indiana 46231

Trade Name(s): Carrier or Bryant

Product: Evaporator coil units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11 (UL 1995)

Laboratory: Intertek Testing Services (ITS)

Test Report(s): ITS File 3079462, dated March 1, 2007.

Description: Upflow / downflow evaporator coil units using R-22 as the refrigerant. Units are comprised of evaporator coils, capillary tubing, and condensate pans. Units, with model numbers and nominal cooling capacities, are listed below.

Model Number	Mfr's Specified Nominal Cooling Capacity, Tons
40BNC009*	0.67
40BNC012*	1
40BNC018*	1.5
40BNC024*	2
40BNC030*	2.5
40BNC036*	3

Terms and Conditions: The above-described evaporator coil units are accepted under the following conditions:

1. Units shall use only Refrigerant R-22.
2. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance September 25, 2007

Examined By Sun Deshpande