



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 617-06-M

Manufacturer: Kinetics Noise Control, Inc., 6300 Irelan Place,
Dublin, Ohio, U.S.A. 43017

Trade Name(s): IsoMax

Product: Resilient sound isolation wall and ceiling clip

Pertinent Code Section(s): 27-323, 27-324, 27-341

Prescribed Test(s): RS 5-2 (ASTM E119)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File R21612, Project 03NK35716, dated April 20,
2004

Description: A combination rubber and metal clip designed to resiliently hold a drywall hat channel to a stud or joist. The IsoMax resilient sound isolation shall be applied in accordance with manufacturer's instruction and Underwriters Laboratories, Inc.'s, Design number U419 listed below, in achieving the required fire resistance rating:

Design No. – U419
Non-bearing wall rating – 1, 2, 3 or 4-hour

Terms and Conditions: The above-described non-load-bearing fire-rated wall assembly is accepted under the following conditions:

1. Structural requirements shall comply with Subchapter 10, Reference Standard RS 10-3 and other applicable provisions of the New York City Building Code.

2. The acceptance of this assembly is limited to fire resistance only. Structural and other requirements shall be in accordance with pertinent Building Code, Underwriters Laboratories, Inc.'s and the manufacturer's requirements.
3. All shipments and deliveries of such equipment shall be provided with a label, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 30, 2007

Examined By Sjoen Derkholm