



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 62-05-E Vol.2

Manufacturer: System Sensor, Unincorporated of Honeywell International Inc., 3825 Ohio Avenue, St Charles, IL 60174

Trade Name(s): Honeywell

Product: Fire Alarm Equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR)

Prescribed Test(s): UL 38

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL Multiple Listing File No. S749, issued 8/4/05

Description – Fire Alarm Pull Boxes

Honeywell Model No.	System Sensor Model No.	Description
S464H1006	20-164	Fire Alarm Pull Boxes

Terms and Conditions: The above units are accepted on condition that:

1. The model S464H1006 non metallic pull box shall be mounted to an approved outlet box of metallic construction.

2. All uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of the new York City Building Code, specifically Subchapter 17 and Reference Standard 17-3.
3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
4. .All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 1, 2006

Examined by Donald [Signature]