



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 622-06-E

**Manufacturer:** System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** System Sensor

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** RS 17-3, RS 4-6 (886-89-BCR)

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S911, Projects 04CA29022 and 05CA05617, issued April 4, 2004, revised June 24, 2005.

**Description:** Detector sounder base, Model EBS, for use with manufacturer's models ED-PTI, ED-PT, ED-PI and ED-P smoke detector heads; ED-TI and ED-T heat detector heads.

Detector relay base, Model EBR, for use with manufacturer's models ED-PTI, ED-PT, ED-PI and ED-P smoke detector heads; ED-TI and ED-T heat detector heads.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 2, 2007, F.P. Index #0612037.

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation, RS 17-5 (NFPA 72) and UL standard.
3. The above product shall be used only with listed, approved/accepted compatible detector heads and fire alarm equipments.
4. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance January 23, 2007  
Examined By Donald [Signature]