



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 631-06-M

Manufacturer: Hilti, Inc., 5400 S. 122 E. Avenue, Tulsa, OK 74146

Trade Name(s): Hilti

Product: Fill, void or cavity material for fire protection

Pertinent Code Section(s): 27-345

Prescribed Test(s): RS 5-19 (ASTM E814)

Laboratory: Underwriters Laboratories, Inc

Test Report(s): UL File R15431, dated March 6, 1995; UL letter dated February 2, 1999.

Description: Fill, void or cavity material for through-penetrations in fire-rated wall and floor construction. The Hilti CP-644 Firestop Collar shall be applied in accordance with Underwriters Laboratories, Inc. system number listed below in achieving the required fire resistance ratings.

System No.	Fire Protection Ratings (Hours)	
	F	T
CAJ2109	3	0,2,3
CAJ2283	2	2
CAJ2284	2	2
CAJ2285	2	2
WL2078	1,2	1,2

Terms and Conditions: The above-described fill, void or cavity material, used to fill the remaining voids in wall assemblies with the above-described fire protection ratings, is accepted with the following conditions:

1. Electrical trays, cables, mechanical piping or ductwork passing through the assembly shall be installed in accordance with UL system numbers and the manufacturer's application instructions.
2. Suitable support angles and fasteners are required for respective assemblies and shall be provided in accordance with manufacturer's recommendations.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance February 15, 2007

Examined By Seun Derkhdam