



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 67-02-E Vol.13

Manufacturer: Honeywell International
12 Clintonville Road
Northford, CT 06472-1653

Trade Name(s): Gamewell-FCI

Product: Fire alarm equipment

Pertinent Code Section(s): 27-968 thru 29-777, RS 17

Prescribed Test(s): §27-969 (UL 38)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing file S281 issued April 5, 2004, revised January 9, 2008.

Description: The Gamewell-FCI addressable single action fire alarm pull station, Model MS-7ASF, is multiple listed with Notifier's addressable dual action, model NBG-12LX (MEA 67-02-E)

| Gamewell-FCI Model No. | Notifier Model No. | Description |
|------------------------|--------------------|-------------------------------------|
| MS-7ASF | NBG-12LX | Addressable Fire Alarm Pull Station |

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, configurations, arrangements and functions, applications and installations shall comply with the New York City Building Code, specifically Subchapter 17 and Reference Standards RS 17-3 and RS 17-5, the UL listing, UL 38 standard, the manufacturer's instructions, the Fire Department rules and the New York City Electrical Code.
2. The referenced product shall only be used with listed and approved fire-control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 29, 2008.
Examined By Donald [Signature]